



Volkert, Inc.
3809 Moffett Road (36618)
P.O. Box 7434
Mobile, AL 36670-0434

July 8, 2016

Office 251.342.1070
Fax 251.342.0962
volkert@volkert.com

Contract No. SEW002-16/Bid No. 026-16
(Volkert Project No. 630106-A)
Cleaning and Inspection of Sanitary Sewer Mains

www.volkert.com

TO: ALL PLAN HOLDERS

SUBJECT: ADDENDUM NO. 2

The following revisions are hereby added as Addendum No. 2 to the referenced project plans and specifications. These items shall be considered when preparing proposals for the construction of this project:

1. Disposal of the liquid only from mainline cleaning operations shall be decanted into the sanitary sewer system when coordinated with the Owner. The Contractor may utilize the Owner's headworks at their Water Resource Recovery Facility for disposal of both liquids and solids at no cost to the Contractor. Available times and rate of disposal shall be coordinated with the Owner to prevent interference with the treatment process. Large debris such as bricks, concrete, and stones that could damage the equipment will not be allowed.
2. It is not the intent of the Owner to use this contract for emergency cleaning. Therefore, delete all references to emergency cleaning.

Receipt of this Addendum No. 2 shall be acknowledged in the appropriate location of Proposal Page II-3 for proposal consideration.

Sincerely,

Tim E. Patton, P.E.
Vice President

/kvd

c Mr. Dan McCrory

Office Locations:

Birmingham, Foley, Mobile, Montgomery, Alabama • Chipley, Ft. Myers, Gainesville, Pensacola, Tampa, Florida
Atlanta, Columbus, Georgia • Collinsville, Wheaton, Illinois • Baton Rouge, New Orleans, Slidell, Louisiana
Jackson, Mississippi • Jefferson City, Missouri • Raleigh, North Carolina • Harrisburg, Pennsylvania
Chattanooga, Nashville, Tennessee • Alexandria, Chesapeake, Virginia • Washington, D.C.

