

**ADDENDUM NO 03
CITY OF FAIRHOPE**

Bid No. 010-17 SLUDGE REMOVAL SERVICES 2017

The following questions have been submitted by potential bidders and answers have been provided by the Superintendent of Water/Sewer Department, Dan McCrory:

Question 1: What is the current stabilization material being used, quick lime, cement kiln dust, etc?

Answer 1: Lime

Question 2: What is the current ratio for stabilization of the bio-solids?

Answer 2: Do not have that in at this time

Question 3: With Class B land application as an extremely viable option, would the City consider stabilization to meet Class B requirements and land application of the material? This would result in significant savings versus treating to Class A requirement

Answer 3: Class A EQ under 40 CFR 503 will ONLY be accepted

Bidders are to sign and include signed **Addendum No. 3** with submitted bid documents.

Acknowledged:

Company

By

Daniel P. Ames
Purchasing Manager
City of Fairhope
Posted: 1/10/17