

ADDENDUM NO 02
CITY OF FAIRHOPE

Bid No. 008-17 LIFT STATION ODOR CONTROL CHEMICAL 2017

The following questions have been submitted by potential bidders and answers have been provided by the Superintendent of Water/Sewer Department, Dan McCrory and Purchasing Manager, Dan Ames:

Question 1: **“The technology that we use is not liquid but is in a tablet form. We are a global company, with our product being used all over the world. Would the City of Fairhope consider looking at our technology?”**

Answer 1: Our bid is currently posted, with specifications concurrent with methods acceptable to the City. However, the City is aware of changing technologies, and would be agreeable to learning more about your technology for future bids

Question 2: **I would like to submit a bid for the odor control contract. Would it be possible to get a water analysis to do our due diligence before our submission? We just want to be as accurate as possible.**

Answer 2: Yes. Potential bidders may schedule a time with the Sewer Department for obtaining a sample. However, sample accuracy will not be as good as we are treating and cannot turn it off

Question 3: **Can we use multiple chemicals?**

Answer 3: Yes, as long as it does not interfere with our treatment processes.

Question 4: **Will someone meet the chemical delivery?**

Answer 4: Yes, only to unlock and open gates.

Question 5: **Do you know what the sulfide levels are? How often are they tested?**

Answer 5: Sulfide levels are checked when the vendor shows up for their visit every six weeks and the program is adjusted if necessary.

Question 6: **If we have flow meters in place, would it be okay to check every 6 months?**

Answer 6: Equipment has to be shown to be in calibration quarterly, any time the City requests it.

Question 7: **Are single walled tanks okay to use?**

Refer to your MSDS

Question 8: **Are there safety showers at any of the stations? Can we put in if desired? And will the City provide the water?**

Answer 8: No. Yes. Yes.

Question 9: **The City is Responsible for the grease mats?**

Answer 9: Yes.

Question 10: Does the City want low profile tanks in neighborhoods?

Answer 10: All tanks must be hidden from view inside fenced area, or inside the building if there is no fence.

Question 11: Can you provide the length and size of discharge line?

Answer 11:

1. White Grove to Thompson Hall	4639	6 inch
2. Thompson Hall to Dog House	10102	10 inch
3. Grand Hotel to Twin Beech	11140	8 inch
4. Point Clear Court is part of Grand Hotel Twin Beech		
5. Twin Beech to South Section	6116	8 inch
6. End of County Rd 1 to Baldwin 1	26832	6 inch
7. Baldwin 1 to Grand Hotel	29936	6 inch
8. Rohr to South Section St	24711	10 inch
9. East of the Sun to discharge point	5174	6 inch
10. Quail Creek to Thompson Hall	8183	10 inch
11. Woodlands to North Section St	6641	10 inch
12. Southland to Fairfield	2530	6 inch
13. Carya Point to Meadowbrook	3088	4 inch

Question 12: Is a bid bond required for this?

Answer 12: Yes. Under **Item II, 2.07 BID SECURITY:**

Bids shall be accompanied by a Bid Security equal to 5% (percent) of the bid price, but in no event more than \$10,000.00. Bid Security shall be in the form of a Bid Bond or a cashier's check payable to the City of Fairhope. No Bid Security is required on bids less than \$10,000.00.

Base your bid bond on the "Annual Total" you submit on Item III, Bid Response Form.

Bidders are to sign and include signed **Addendum No.2** with submitted bid documents.

Acknowledged:

_____ Company

_____ By

Daniel P. Ames
Purchasing Manager
City of Fairhope
Posted: 1/19/17

**NON-MANDATORY
PRE-QUOTE MEETING ATTENDANCE ROSTER
CITY OF FAIRHOPE, AL**

MEETING DATE: 01/17/2017, 8:00 Tuesday

BID 008-17 Lift Station Odor Control Chemical 2017

PRINT VERY CLEARLY!!! IF YOUR INFORMATION IS NOT READABLE, YOU WILL NOT RECEIVE EMAILS.

REP'S NAME	COMPANY	PHONE	EMAIL
Afsary Ahmed	USP Technologies	917 225-9674	aaahmed@usptechnologies.com
Stephen Vorce	Evogva	770-479-8074	stephen.vorce@evogva.com
SCOTT SCHRADER	HARRINGTON	251/402-7182	sschrader@h.pco.com

Dee Dee Brandt	COF		deedeeb@fairhopeal.gov
Dan McCree			
Jay Whitman			