

ADDENDUM NO 03
CITY OF FAIRHOPE

RFQ No. 002-17 Supply Zinc Orthophosphate and TKPP Chemicals 2017

The following questions have been submitted by potential bidders and answers have been provided by the Superintendent of Water/Sewer Department, Dan McCrory:

Question 1: We noticed an issue with ITEM 1: “Invitation & Instructions to Vendors”, specifically in 4.0 **TECHNICAL SPECIFICATIONS:**
“4.03: All supplied chemicals must be EPA Approved for drinking water.”

The EPA does **not** have a list of Approved chemicals for drinking water. Therefore, this requirement in the RFQ is not valid and no one will be able to meet this requirement.

Answer 1: **This should be changed to:**

4.03: All supplied chemicals must be ANSI/NSF Standard 60 Approved for drinking water.

Bidders are to sign and include signed **Addendum No.3** with submitted bid documents.

Acknowledged:

By

Daniel P. Ames
Purchasing Manager
City of Fairhope
Posted: 4/03/17