

ADDENDUM NUMBER 4

Friday, May 4, 2018

PROJECT:
FAIRHOPE LIBRARY ENVELOPE REPAIRS
FAIRHOPE, ALABAMA
GMC PROJECT NO. AMOB170026

AD4-1 GENERAL:

- A. The following revisions and/or additions to the Drawings and Project Manual are hereby made a part of same, and shall be incorporated in the Work of the Contract the same as if originally included in the Bid and Construction Documents.
- B. Bidders shall acknowledge receipt of the Addendum in writing, as provided on the Acknowledgment Receipt.
- C. When a revision and/or addition is called for to the Drawings or Project Manual, they shall be fully coordinated with and carried through all applicable Drawings and portions of the Project Manual.

AD4-2 CLARIFICATIONS:

- A. For ALL design pressure (wind load) references: Project design pressures shall be based on a **160 MPH** design wind load and design pressures as follows: Fabricators shall be responsible for calculating their own loads and pressures based on their own design and materials.

AD4-3 ATTACHMENTS:

- A. Addendum Acknowledgment Response

END OF ADDENDUM

PREPARED BY

GMC

Goodwyn Mills Cawood
11 North Water Street
Suite 15250
Mobile, Alabama 36602
T 251.460.4006
F 251.460.4223





Goodwyn Mills Cawood
11 North Water Street
Suite 15250
Mobile, Alabama 36602
T 251.460.4006
F 251.460.4423

FASCIMILE TRANSMITTAL COVER SHEET

DATE: May 4, 2018
TO: Katie Fowler
FROM: Planholder
PROJECT: FAIRHOPE LIBRARY ENVELOPE REPAIRS
For FAIRHOPE, ALABAMA
GMC PROJECT NO. AMOB170026
RE: ADDENDUM NO.4 AND ACKNOWLEDGEMENT OF RECEIPT OF ADDENDUM NO. 4

ACKNOWLEDGEMENT OF RECEIPT:

PLEASE PRINT RECIPIENT'S NAME, FIRM, AND DATE RECEIVED.

THEN FAX BACK TO (251) 460-4423 or EMAIL Katie.Fowler@gmcnetwork.com
FOR OUR RECORDS AND TO ACKNOWLEDGE YOUR RECEIPT OF THIS ADDENDUM.

NAME (PLEASE PRINT)

FIRM (PLEASE PRINT)

DATE RECEIVED (PLEASE PRINT)