

**ADDENDUM 1**  
CITY OF FAIRHOPE

**Bid 015-20 Consecutive Replacement of Wells 1 and 8**

Question 1: I see the pump schematics were included in the bid documents but no well schematics?

Answer 1: Well schematics included in this addendum.

Bidders are to sign and include signed **Addendum 1** with submitted bid documents.

Acknowledged:

---

Company

---

By

Purchasing Manager  
City of Fairhope  
Posted: 1/15/2020

REPORT OF DRILLED WELL

Well #1

Carloss Well Supply Co. 1083 111 North Parkway Mphs, Tn. 38103 14 Nov. 75  
 DRILLING CONTRACTOR License Number Address Zip Code Date  
 City of Fairhope, Ala. - P. O. Drawer 429 36532  
 PROPERTY OWNER Address (mailing) Zip Code

WELL LOCATION Baldwin 15 S.W. 1/4 S. 21 E. Range 7 E  
 County Section 1/4 Section Township Range  
 Northside of Fairhope Ave. Extended - Behind Fairhope Ave. Baptist Church  
 Distance and direction from nearest town, community, road junction or other reference point

WELL WILL BE USED FOR:  
 CWS Well No. 2 (Production)  Private supply  
 CWS Well No. 1 (Production)  Public supply  
 Industrial supply  Test well  
 Irrigation Other: \_\_\_\_\_

January 1974 Drilling Method: Cable tool  
 Rotary Jettled Bored  
 Hack Other: \_\_\_\_\_

20" Diameter of well 223' Estimated depth  
 ORIN JOHNSON VICE PRESIDENT  
 SIGNATURE of Drilling Contractor

Total Depth 223' Completion Date October 1975

Interval	Description of cuttings	Interval	Description of cuttings	Completion date: report depth, below ground level
1'	Top Soil			Pump Type: <input checked="" type="checkbox"/> Turb. <input type="checkbox"/> Subm. <input type="checkbox"/> Jet <input type="checkbox"/> Cyl.; Other: _____ Intake depth 160 H.P. 40 Yield: 750 gpm
5'	Yellow Clay			
20'	Hard Clay (multicolored)			Capacity Tested by: <input checked="" type="checkbox"/> pumping <input type="checkbox"/> air lift <input type="checkbox"/> bailer <input type="checkbox"/> none Measured Static Water Level 71.5 ft Measured pumping level 121.5 ft. after 24 hrs. pumping 750 gpm Development time prior to testing 24 hrs.
34'	White Sand w/strks white clay			
127'	Brown Sand, Pea Gravel w/strks clay			Finish <input type="checkbox"/> Open hole <input checked="" type="checkbox"/> Screened <input type="checkbox"/> Sotted pipe <input checked="" type="checkbox"/> Gravel pack Interval(s) screened: 158' to 218' ft. Packer(s) set at _____ and _____ ft. Screen: diam 12 3/4 OD; Size openings .030"
216'	Coarse Sand w/small pea gravel			
218'	Orange Clay			Casing Interval cased Diam. (inches) *Type pipe *Type couplings Interval gravel 154' 20" Bld. Stl. (w) All *Couplings: Threaded & Coupled (T&C) Welded (W) Threaded & coupled & welded (TC&W) Other: _____ *Pipe: Black; PVC; Galv.; Other: _____
234'	Blue Clay w/strks sand			
278'	Loose Fine Sticky Sand			Quality Water analysis obtained? (check) <input type="checkbox"/> No <input checked="" type="checkbox"/> Bacteriological <input checked="" type="checkbox"/> Chemical Analysis by: <input type="checkbox"/> Ala Geol. Surv. <input type="checkbox"/> U.S. Geol. Surv. <input checked="" type="checkbox"/> Ala Health Dept. <input checked="" type="checkbox"/> Private lab.
308'	Sandy Shale			
338'	Blue Sticky Sand Shale			Signed: Carloss Well Supply Co.
367'	Hard Blue Sandy Shale			
395'	Sandy Shale w/hard strks Blue Clay			
471'	Hard Packed Med. Grey Sand			
509'	Hard Clay w/strk sandy shale			
531'	Sand			
536'	Hard Shale			
547'	Sandy Shale w/hard streaks			
598'	Hard Shale w/thin strks sand			
599'	Hard Rock			
609'	Hard Sandy Shale			

\*For deeper well please attach continuation sheet

Large, color, etc.

Analysis by: Ala Health Dept. Private lab.

**CITY OF FAIRHOPE  
WELL NO. 8  
AS-BUILT SCHEMATIC  
N.T.S. (5/14/01)  
Griner Drilling Service, Inc.**

