

**ADDENDUM 1**  
CITY OF FAIRHOPE

**Bid 008-21 Nichols Substation Fence**

The following information should be added to the fence specifications:

The fence fabric shall be of galvanized two-inch (2") chain link mesh, #9 gauge, as manufactured by Page, Cyclone or approved equal. The fence shall be eight feet (8') in height (7' of fabric and 1' of barbed wire) with suitable fittings for three (3) strands of barbed wire extended above the fabric.

Bidders are to sign and include signed **Addendum 1** with submitted bid documents.

Acknowledged:

\_\_\_\_\_  
Company

\_\_\_\_\_  
By

Purchasing Manager  
City of Fairhope  
Posted: 11/16/2020