

Fairhope Municipal Pier – 1 Fairhope Avenue
Repair of Damaged Utility Tray – Hurricane Zeta
City of Fairhope Public Works Project No. MP-Zeta-20
Addendum #1 to Bid Response:

Addendum Number: One (1)

Date Issued: February 19, 2021

CHANGE IN UTILITY INSTALLATION SPECIFICATIONS:

3. Sewer

- a. Low pressure sewer line should be 1-1/2" (IPS) PE minimum DR 11 Pressure Class 200 with green stripe running entire length of pipe. Pipe shall be one continuous length no cuts and/or joints (fusing) should be required. Restrained by corrosion resistant hardware spaced according to engineer/owner recommendations.

Commentary: The Sewer Utility has determined that they can pump all effluent through a 1-1/2" line. Since the PE pipe comes in 1000' rolls, it can be installed continuously without cutting and/or fusing. This should reduce project scope of work, labor and material cost required.

Bidders are to sign and include signed **Addendum 1** with submitted bid documents.

Acknowledged:

Company

By

Purchasing Manager
City of Fairhope
Posted: 2/19/2021