



ADDENDUM No. 02

TO

CONTRACT DOCUMENTS & CONSTRUCTION SPECIFICATIONS

FOR

City of Fairhope

**BID NO. 034-21- PHASE 2—PROJECT 2—Bayou Drive, Fairwood Blvd. And Fairhope Av
Transmission System—
IMPROVEMENTS FROM FAIRHOPE AVE AT INGLESIDE TO NORTH HILLS SUBDIVISION
PHASE 2A— IMPROVEMENTS FROM FAIRHOPE AVE AT INGLESIDE TO BISHOP AVE
Project No. SEW002-18 Wastewater Collection and Transmission System Improvements**

The bid documents for this Bid shall be amended, revised and changed in the following particulars:

- 1. If the contractor so chooses, Fusible C900 PVC 16” DR 18 will be an acceptable alternative for the 16” HDPE DR 11. Contractor will be responsible to make the necessary adjustments needed to accommodate the change in retainer glands, MJ adaptors, and fosters adaptors.**

- 2. If the contractor so chooses 16” HDPE DR 11 will be an acceptable replacement for the open cut PVC C-900 DR 18 included in the quantities. Contractor will be responsible for making necessary adjustments in retainer glands, MJ adaptors, and fosters adaptors.**

Submitted by:

Dewberry Engineers, Inc.



Andrew N. Bobe

Responders are to include signed Addendums with submitted bid documents. Addendums shall be attached to front cover of bid document.

Acknowledged:

_____ Company

_____ By

_____ Date