

**ADDENDUM NUMBER 4**

**DATE:** October 15, 2021

**PROJECT:** 2021 Distribution and 46 KV Line Additions and Improvements  
City of Fairhope

**BID NO.:** 038-21

**PROJECT NO.:** ELE002-21

**FROM:** Stewart Engineering, Inc.  
PO Box 2233  
300 East 7th Street  
Anniston, AL 36202  
(256) 237-0891

**TO:** BIDDERS

This addendum forms a part of the Contract Documents and modifies the original Construction Documents, Drawings and Specifications dated August, 2021 as noted below.

1. Contractor shall be responsible for drilling the following 10 Ductile Iron and Steel poles: # 52, 54, 55, 56, 57, 58, 60, 90, 91, and 107. The remaining 18 Ductile Iron and Steel poles shall be ordered pre-drilled.

The rock for the Ductile Iron and Steel poles, which shall be supplied by the Owner, will be stock piled at their Twin Beech Substation (7471 Twin Beech Road). The Owner will have equipment on site at the Twin Beech Substation to load the rock on the Contractor's truck. The Contractor shall be responsible for hauling the rock to the job site, and unloading it as required.

Acknowledgement of this Addendum must be made at the time of bid.

\_\_\_\_\_  
Bidder

\_\_\_\_\_  
Date

END OF ADDENDUM NO. 4

STEWART ENGINEERING, INC.  
Lance Junkin