

ADDENDUM NO 04

CITY OF FAIRHOPE

to

Bid No. 020-13 Community Park Fencing Project No. REC003-13 Community Park Fencing

The bid documents for this Bid shall be amended, revised and changed in the following particulars provided by the Purchasing Manager and the Recreation Department:

CLARIFICATION

1. The north fence line will be constructed on the same line as the existing chain link fence, with two exceptions: The northwest corner of the new fence line will be located four (4) feet further to the west than the current chain link corner post (longer); and the northeast corner post of the new fence will be located two (2) feet west of the current chain link corner post (shorter).
2. The west fence line will be constructed parallel to the existing chain link fence line, offset four (4) feet to the west, to avoid the existing tree line. A stake with blue ribbon has been placed approximately on line, and next to the root system of a large water oak that is to be avoided. The Director of Public Works would like the west line fencing to begin approximately at this point, and work outward to the northwest, and southwest fence corners, avoiding as many roots as possible.
3. The south fence line will be constructed on the same line as the existing chain link fence, with two exceptions: The southwest corner of the new fence line will be located four (4) feet further to the west than the current chain link corner post (longer); and the southeast corner post of the new fence will be located ten (10) feet west of the current chain link corner post (shorter).
4. The east fence line will be constructed in the following line:
 - a. From the new northeast corner post, proceed southward approximately sixty seven (67) feet and set a new corner post approximately four (4) feet west of the existing property line.
 - b. From that corner post, proceed two (2) feet eastwardly and set a corner post.
 - c. From that corner post, proceed approximately seventy three (73) feet parallel to the existing fence line, and set a corner post (this should be approximately two (2) feet offset from the existing fence line corner post).
 - d. From that corner post, proceed westerly approximately nine feet seven inches (9'-7") and set a new corner post.
 - e. From that corner post, proceed southward approximately ninety six (96) feet and set a new post approximately sixteen(16) inches west of the existing property line.
 - f. From that post, proceed southward approximately fifty eight feet (58) feet and set a new corner post approximately sixteen(16) inches west of the existing property line. This post should be approximately one foot five inches (1'-5") short of the south end of the small stone wall along that portion of the property line.
 - g. From that corner post, proceed approximately twenty four (24) feet diagonally in a southwesterly direction and set a post adjacent to the new aluminum fence southeast corner post. On the south fence line, this should be approximately ten (10) feet short of the existing chain link fence southeast corner post.
5. All measurements are approximate, and should be field verified by the bidders before submitting bids.
6. Omit the walk gate on the north fence line, replace that area with the specified aluminum fence.
7. The sketch referred to in addendum no. 3 has been omitted. Refer to written location description above.

QUESTION FROM POTENTIAL BIDDER

Question:

"The aluminum fence diagram shows a flat-top fence and the written specs mentions rings, section 8.02.1.1. Does the aluminum fence have rings or not?"

Answer:

The rings are decorative, and placed between the top rail, and a secondary horizontal rail just below the rings. See accompanying photo showing a sample style. The ring design is variable, we are most interested in some decoration, but not pointed ones that are not be best suited for a children's park.

REMINDER (POSTED IN ADDENDUM 3, BUT WORTH REPEATING)

1. The bid opening time is changed
from: Tuesday, June 11, 2013 at 10:00 a.m.
to: Tuesday, June 18, 2013 at 10:00 a.m.

Responders are to sign and include signed Addendum No.4 with submitted bid documents.

Acknowledged:

Company

By

Daniel P. Ames
Purchasing Manager
City of Fairhope
Posted: 06-11-2013

