



thompson  
ENGINEERING

**Addendum No. 1**

To: All Bidders

From: Matt Rogers

Date: August 15, 2022

**RE: Pump Station and Force Main Improvements – Phase II  
Thompson Engineering Project No. 22-1101-0257**

The plans and specifications for the above referenced project are hereby revised as follows:

**General:**

- The bid opening will be moved from August 24, 2022 to September 7, 2022 at 10:00 a.m. This will extend the deadline for questions and last opportunity to pick up bid documents as well. These new dates are listed below.
- Contract time has been extended to 365 calendar days. This should allow for additional time required to acquire materials.
- Notice to proceed will be issued within 15 days of the final execution of the contract. However, the City/Engineer will coordinate with the contractor to determine the date that time charges will commence based on the anticipated delivery date of materials.
- If applicable, liquidated damages will be assessed in accordance with the latest ALDOT Standard Specifications for Highway Construction Section 108.11.
- Engineer will coordinate with ALDOT and/or Baldwin County Highway Department (as necessary) for any utility permits.

**Revised Bid Form:**

A revised bid form is attached which indicates “Revised per Addendum No. 1” in the header and includes the following changes.

- Added Pay Item No. 641J526 – 16 Inch Gate Valve with Box (Resilient Seated Gate Valve), 8 EA.
- Removed Pay Item No. 641K522 – 16 Inch Butterfly Valve with Box.
- Revised description of Pay Item No. 645A678 – 12 Inch HDPE Sanitary Sewer Force Main Pipe Laid (All Depths) to specify directional bore installation. Adjusted quantity to 4250 LF.
- Added Pay Item No. 645A679 – 12 Inch HDPE Sanitary Sewer Force Main Pipe Laid (All Depths) (Open Cut installation), 250 LF.
- Revised description of Pay Item No. 645A682 – 16 Inch HDPE Sanitary Sewer Force Main Pipe Laid (All Depths) to specify directional bore installation. Adjusted quantity to 16830 LF.

Alabama | Florida | Georgia | Louisiana | Mississippi | North Carolina | Tennessee | Texas

2970 Cottage Hill Rd. Ste. 190 Mobile, AL 36606  
thompsonengineering.com | 251.666.2443



thompson  
ENGINEERING

- Added Pay Item No. 645A683 – 16 Inch HDPE Sanitary Sewer Force Main Pipe Laid (All Depths) (Open Cut installation), 470 LF.
- Added Pay Item No. 645C500 – Ductile Iron Fittings, 6650 LBS.
- Remove Pay Item No. 645M500 – Connection to Existing Manhole.
- Remove Pay Item No. 649A640 – 14 Inch Steel Encasement Pipe, Type 2 Installation.
- Remove Pay Item No. 649A650 – 18 Inch Steel Encasement Pipe, Type 2 Installation.
- Added Pay Item No. 649A665 – 30 Inch Steel Encasement Pipe, Type 2 or 3 Installation, 190 LF.
- Revised quantity for Pay Item No. 654A000 – Solid Sodding to 1520 SQ YD.
- Removed Pay Item Nos. 740D000 – Channelizing Drums; 740E000 – Cones (36 Inches High); and 740M001 – Ballast for Cone. These items will be included under Pay Item No. 740A000 – Traffic Control Scheme, 1 LS.

**Revised Plan Set:**

A conformance set of plans will be issued to the lowest responsive bidder which will include the following revisions.

- On sheet G101, the following note has been added: “21. The contractor shall provide shoring in accordance with latest OSHA regulations for all trenches in excess of 5’ in depth.”
- On Sheet G102, the summary of quantities will be revised in accordance with revised bid form noted above.
- On Sheet C402, the note near Sta. 37+00 indicating a 12” 90° bend has been revised to indicate a 16”x12” tee. Additionally, the encasement pipe between Sta. 200+00 and Sta. 201+00 has been omitted.
- On Sheet C404, the encasement pipe between Sta. 60+90 and Sta. 61+90 has been omitted. Additionally, the notes near the intersection of County Road 13 and Gayfer Road have been adjusted to match the pipe alignment.
- On Sheet C410, the encasement pipe between Sta. 156+00 and Sta. 157+00 has been upsized from 18” to 30”.

**Important Dates:**

- August 17, 2022 – Pre-bid Meeting
- August 22, 2022 – No questions (oral or written) will be addressed after 12:00 p.m.
  - a. Extended from August 19, 2022
- September 6, 2022 – No bid packages will be issued after 10:00 a.m.
  - a. Extended from August 23, 2022
- September 7, 2022 – Bid Opening – 10:00 a.m.
  - a. Extended from August 24, 2022

The bidders on this project are advised to email a signed copy of this sheet to the office of Thompson

Alabama | Florida | Georgia | Louisiana | Mississippi | North Carolina | Tennessee | Texas

2970 Cottage Hill Rd. Ste. 190 Mobile, AL 36606  
thompsonengineering.com | 251.666.2443



thompson  
ENGINEERING

Engineering Inc. ([mrogers@thompsonengineering.com](mailto:mrogers@thompsonengineering.com)) prior to Friday, September 2, 2022 at 12:00 PM. **A copy of the entire addendum (all 4 pages) must be stapled to the inside front cover of the bid book. The modified bid form (see attached) shall be used.** If you have any questions regarding this addendum, please contact our office.

Sincerely,  
Thompson Engineering Inc.

Matthew C. Rogers, P.E.  
Municipal & Utility Team Lead

SIGNED:

\_\_\_\_\_  
Company Name

\_\_\_\_\_  
Contractors Representative

\_\_\_\_\_  
Date

**ITEM III  
BID RESPONSE FORM**

The following items shall be constructed in accordance with the *Alabama Department of Transportation Standard Specifications for Highway Construction*, Current, Non-metric Edition, except as modified herein.

Notes:

1. The following unit prices shall include all labor, materials, equipment rental, overhead, profit, insurance, etc., to cover the finished work of the several kinds called for.
2. Bidder understands that the Owner reserves the right to reject any and all bids.

| Item No. | Description   | Unit        | Quantity | Unit Price | Total Amount |
|----------|---|-------------|----------|------------|--------------|
| 600A-000 | Mobilization  | Lump Sum    | 1        |            |              |
| 641I-515 | 2 Inch Air Release Valve  | Each        | 17       |            |              |
| 641J-526 | 16 Inch Gate Valve with Box (Resilient Seated Gate Valve)                                     | Each        | 8        |            |              |
| 641L-900 | Concrete for Sanitary Sewer Force Main (Thrust Blocks)  | Each        | 13       |            |              |
| 645A-678 | 12 Inch HDPE Sanitary Sewer Force Main Pipe Laid (All Depths) (Directional Bore Installation) | Linear Foot | 4250     |            |              |
| 645A-679 | 12 Inch HDPE Sanitary Sewer Force Main Pipe Laid (All Depths) (Open Cut Installation)         | Linear Foot | 250      |            |              |
| 645A-682 | 16 Inch HDPE Sanitary Sewer Force Main Pipe Laid (All Depths) (Directional Bore Installation) | Linear Foot | 16830    |            |              |
| 645A-683 | 16 Inch HDPE Sanitary Sewer Force Main Pipe Laid (All Depths) (Open Cut Installation)         | Linear Foot | 470      |            |              |
| 645C-000 | Ductile Iron Fittings   | Pound       | 6650     |            |              |
| 649A-665 | 30 Inch Steel Encasement Pipe, Type 2 or 3 Installation                                       | Linear Foot | 190      |            |              |
| 650A-000 | Topsoil, 4" Thick   | Cubic Yard  | 100      |            |              |
| 654A-000 | Solid Sodding   | Square Yard | 1520     |            |              |
| 665O-000 | Temporary Erosion Control   | Lump Sum    | 1        |            |              |
| 740A-000 | Traffic Control Scheme  | Lump Sum    | 1        |            |              |
| Total:   |   |             |          |            |              |