



December 5, 2022

Addendum 2

Bid No. 23-010-2023-PW-008F

New Volanta Baseball Field Fencing

Addendum 2 contains questions and answers submitted via email.

This bid will be opened at the City of Fairhope's City Services and Public Utilities Building, 555 South Section Street, Fairhope, AL 36532 at 2:00 PM on Thursday, December 8, 2022. Vendors shall acknowledge this Addendum 1 on their submitted Bid Response Form.

Questions Submitted Via Email:

1. On page 11 of the bid package, under "Material – Fence Fabric" part A, can you specify if you want the fabric to be Class 1 – extruded, Class 2A – extruded and bonded, or Class 2B, fused and bonded?
A. Class 2B, fused and bonded.

2. On the last page, in the drawings, all of the posts and metal frame work are specified as galvanized. Can you confirm if the framework is either galvanized or black?
A. Coated (painted) black.