



June 16, 2023

Addendum 4

Bid No. 23-029-2023-PWI-015

The Haven Animal Shelter Major Façade and Remodel

Addendum 4 contains questions and answers submitted via email.

This bid will be opened at the City of Fairhope's City Services and Public Utilities Building, 555 South Section Street, Fairhope, AL 36532 at 2:00 PM on Thursday, June 29, 2023. Vendors shall acknowledge this Addendum 4 on their submitted Bid Response Form.

Questions Submitted Via Email:

1. What is the color of the existing shingles?
A. The shingles are a GAF product and the Vendor is responsible for field verifying the color.

2. What is the roof pitch, and the soffit size?
A. The roof pitch has been calculated at a minimal 3/12. The soffit is a 12" vented vinyl material. The Vendor awarded the contract shall field verify both prior to construction.