



February 2, 2024

Addendum 3

Bid No. 24-015

Bleachers for Founders Park Track Facility

Addendum 3 contains questions and answers submitted via email.

This bid will be opened at the City of Fairhope's City Services and Public Utilities Building, 555 South Section Street, Fairhope, AL 36532 at 10:30 AM on Thursday, February 8, 2024. Vendors shall acknowledge this Addendum 3 on their submitted Bid Response Form.

Questions Submitted Via Email:

1. Length: These grandstands are done in 6' increments with 1.5" overhanging on each end. Therefore, a 69' bleacher would be the correct size. Is this permitted?
A. 69' is acceptable.
2. Aisles: A 10 Row 69' bleacher has to have a minimum of 2 aisles to meet code. However, the specs call out for 1 or 2 aisles. If another bidder bids a bleacher with 1 aisle that does not meet code, they will likely be cheaper. How many aisles do you want the bleacher to have?
A. To meet code, bleachers are required to have two (2) aisles.
3. Capacity: This size bleacher will have approx. 363 seats, is that permitted?
A. Yes. Submitted bid shall state the approximate number of seats for the proposed bleacher design.
4. Risers: The specs call out for 1" x 6" Risers, but addendum says it needs to be fully closed. Only 1" x 8" risers would be able to fully close a bleacher that has an 8" x 24" Rise/Run.
A. Change the riser requirement to 1" x 8" if required to be fully closed.