



July 23, 2024

Addendum 1

Bid No. 24-061

950 Feet 6" Steel Pipe

For Gas Department

Addendum 1 contains questions and answers submitted via email.

This bid will be opened at the City of Fairhope's City Services and Public Utilities Building, 555 South Section Street, Fairhope, AL 36532 at 10:00 AM on Thursday, July 25, 2024. Vendors shall acknowledge this Addendum 1 on their submitted Bid Response Form.

Clarifications:

- The Bid Opening is on **THURSDAY**, July 25, 2024 at 10:00 a.m. All bids must be received prior to that time.

Questions Submitted Via Email:

1. Coating: Is this outer coat Powercrete? If so, please specify mils required.
A. Coating is dual coat fusion bond epoxy (color brown). After coating twice at 14-16 mils the final amount will be roughly 30 mils.
2. Steel Pipe: Is domestic or import accepted?
A. Domestic is required.
3. Is a bond required? If so, how much?
A. Bid Bond is not required.
4. If a bond is required, are Veterans exempt from this requirement?
A. Bid Bond is not required.
5. This bid require that the pipe be made in America or will other countries origin pipe be accepted to bid?
A. Made in America is required.
6. Mill test reports required with delivery?
A. No.