ADDENDUM NO 01 CITY OF FAIRHOPE

To

BID NO. 038-11

THEATRE 98 BUILDING

FOR THE PUBLIC WORKS DEPARTMENT

The bid documents for this Bid shall be amended, revised and changed in the following particulars:

Answers from Engineer of Record, Robbie Strom, HMR, LLC., Project Manager Ken Eslava, Purchasing Manager Dan Ames

Questions from potential bidders:

Question 1:

Can HMR email me or can I have them burn them to my disk, so that I can get them (drawings) in PDF format?

Answer 1:

The drawings are available as stated in the bid packet. Any bidder that wants to convert them to electronic format may do so.

Question 2:

Would that be possible for us to receive a copy or at least the electronic format of the bid form?

Answer 2:

The bid form is available for download in .pdf format at our website: www.cofairhope.com .

Question 3:

Would we be able to get a set tap fee from the utility department that can be added in an addendum to make sure everyone is apples to apples.

Answer 3:

The tap fee for the City Building has been waived.

Question 4:

As for the exterior walls, will all block need to be poured and will they need to have a 2hr rating?

Answer 4:

All exterior walls do not have to be poured but will need to provide a 2hr fire rating in accordance to IBC 2006, as noted in the plans. Walls will need to match the façade of the existing building.

Qı	estion	5
œι	10311011	υ.

What is the specified PSI for the building concrete slab or any other concrete being used?

Answer 5:

See plan sheet 8 of 9 - 4.Reinforced Concrete, note 4.2 in reference to concrete compressive strength.

Responders are to <u>sign and include signed Addendum No. 1</u> with submitted bid <u>documents.</u>

Acknowledged:		
	Company	
	Ву	

Daniel P. Ames Purchasing Manager City of Fairhope Posted: 10-12-2011