

ADDENDUM NO 01
CITY OF FAIRHOPE
To
BID NO. 036-11

SIDEWALK IMPROVEMENTS 2011
FOR THE PUBLIC WORKS DEPARTMENT

The bid documents for this Bid shall be amended, revised and changed in the following particulars:

Answers from Public Works Department, Engineer of Record, Purchasing Manager

Questions from potential bidders:

Question 1:

Are the handrails to be aluminum or galvanized steel?

Answer 1:

All handrails shall be Aluminum.

Question 2:

Will the Bid Response form be modified to include a traffic control line item?

Answer 2:

No separate pay item will be established for traffic control. The Bid Proposal form has line items for all required traffic control devices. No separate payment shall be made for the movement of temporary construction signage due to changing/moving construction operations.

Question 3:

Will the Bid Response be modified to include a truncated MATS line item?

Answer 3:

A pay item has been added to the Bid Proposal form for the installation of tactile warning mats. Contractor shall remove Sheet 2B from the construction drawings and replace with attached revised Sheet 2B.

Question 4:

Will the Bid Response form be modified to include any unclassified excavation line items?

Answer 4:

A pay item has been added to the Bid Proposal form to establish 250 cy of unclassified excavation to be paid on a per cubic yard basis as outlined in the project specifications.

Question 5:

Will Thompson Engineering handle all testing?

Answer 5:

Thompson Engineering has been retained by the owner to provide all necessary construction materials testing as required by the contract documents.

Question 6:

Are there any ongoing city projects in the project area?

Answer 6:

No

Question 7:

Will the concrete mix be to State Specifications?

Answer 7:

All proposed concrete mix designs shall be in accordance with the Alabama Department of Transportation Standard Specifications for Highway Construction, 2008 Edition.

Question 8:

When are grant related forms to be submitted?

Answer 8:

Included in Bid Response

Question 9:

Does this project require certified payrolls?

Answer 9:

Yes

Question 10:

Are there any restrictions on working hours?

Answer 10:


Ken Eslava & Thompson Engineering will work cooperatively together during the course of the sidewalk project, with the successful contractor, to assure safe and effective traffic management in the area of Fairhope High School and Fairhope Middle School. By safe, we mean safe for both the public and our contractor of record.....by effective, we mean a process that does not inhibit or delay the operations of school traffic flow while allowing the project and the contractor to remain on project schedule.

CLARIFICATION:

1. Remove Bid proposal Item II page 4, replace with Bid proposal Item II, page 10 rev 1(SEE ATTACHED).
2. Copies of the complete addendum or available for viewing at City of Fairhope, 555 South Section Street, Fairhope Al. Copies are also available at Thompson Engineering, Inc., 2970 Cottage Hill Road, Suite 190, Mobile, Alabama 36606.

TYPICALS AND MISCELLANEOUS DETAILS


REFERENCE PROJECT NO	FISCAL YEAR	SHEET NO
STPTE-TE09(978)	2011	revised 2B




*** TYPICAL CROSSWALK PAVEMENT MARKING DETAIL**

NTS

* NOTE: NO CROSSWALK PAVEMENT MARKINGS SHALL BE APPLIED TO RESIDENTIAL DRIVEWAYS.



DRAINAGE SECTION



PLAN - TACTILE WARNING SURFACE

NTS



RESPONSIBLE PE:	SUPERVISOR:	DESIGNER:	PLAN SUBMITTAL	ALABAMA DEPARTMENT OF TRANSPORTATION	NOT TO SCALE	SHEET TITLE	ROUTE
DATE:	DATE:	DATE:					

ITEMIZED BID FORM

WITH SPECIAL REGARD TO SPECIFICATION SECTION 102.06, "PREPARATION OF PROPOSAL", AS REVISED BY THE SPECIAL PROVISIONS, THE FOLLOWING REPRESENTS THE BIDDER'S SCHEDULE OF CONTRACT UNIT PRICES FOR THIS PROPOSAL (BIDDER TO COMPLETE BELOW AND SUBMIT):

LINE NO	ITEM NO	DESCRIPTION	QUANTITY	UNIT	UNIT PRICE	AMOUNT BID
1	201A-002	CLEARING AND GRUBBING	1	LUMP SUM		
2	206D-007	REMOVING CONCRETE FLUME	31	LIN FT		
3	210A-000	UNCLASSIFIED EXCAVATION	250	CU YD		
4	210D-000	BORROW EXCAVATION	600	CU YD		
5	301A-012	CRUSHED AGGREGATE BASE COURSE, TYPE B, PLANT MIXED, 6" THICK	125	SQ YD		
6	517D-000	ALUMINUM SIDEWALK HANDRAIL	130	LF		
7	524B-011	CULVERT CONCRETE EXTENSION (CAST IN PLACE)	0.9	CU YD		
8	529-A010	RETAINING WALL	230	SQ FT		
9	535B-011	22" SPAN, 14" RISE SIDE DRAIN PIPE	24	LIN FT		
10	600A-000	MOBILIZATION	1	LUMP SUM		
11	618A-000	CONCRETE SIDEWALK, 4" THICK	5250	SQ YD		
12	618A-003	TRUNCATED DOME TACTILE WARNING STRIP	7	EACH		
13	618B-002	CONCRETE DRIVEWAY, 6" THICK	100	SQ YD		
14	619B-116	22" SPAN, 14" RISE SIDE DRAIN PIPE END TREATMENT, CLASS 1	2	EACH		
15	620A-000	MINOR STRUCTURAL CONCRETE	1.75	CU YD		
16	650B-000	TOPSOIL, 4" THICK	700	CU YD		
17	652A-054	SEEDING	1.8	ACRE		
18	654A-003	SOLID SODDING (CENTIPEDE)	2500	SQ YD		
19	656A-001	MULCHING, CLASS A, TYPE 2	1.8	ACRE		
20	665F-000	HAYBALES	150	EACH		
21	665G-000	SANDBAGS	600	EACH		
22	665J-000	SILT FENCE (TYPE A)	5000	LIN FT		
23	665Q-002	WATTLE	600	LIN FT		
24	674A-000	CONSTRUCTION SAFETY FENCE	2000	LIN FT		
25	680A-000	ENGINEERING CONTROLS	1	LUMP SUM		
26	703A-000	TRAFFIC CONTROL MARKINGS, CLASS II, TYPE A	3440	SQ FT		
27	710A-000	CLASS 4, ALUMINUM FLAT SIGN PANELS 0.08" THICK OR STEEL FLAT SIGN	120	SQ FT		
28	710B-001	ROADWAY SIGN POST (#3 "U" CHANNEL GALVANIZED STEEL)	112	LIN FT		
29	740B-000	CONSTRUCTION SIGNS	236	SQ FT		
30	740D-000	CHANNELIZING DRUMS	75	EACH		
31	740E-000	CONES (36 INCHES HIGH)	50	EACH		
32	740M-001	BALLAST FOR CONE	50	EACH		
33	741C-010	PORTABLE SEQUENTIAL ARROW AND CHEVRON SIGN UNIT	1	EACH		

TOTAL BID AMOUNT \$

Responders are to sign and include signed Addendum No.1 with submitted bid documents.


Acknowledged: _____
Company

By

Approved for posting

Krista Landenwich _____ 09-22-11

Krista Landenwich P.E., Engineer of Record
Thompson Engineering, Inc.



(seal)

Posted: 09-22-11
Daniel P. Ames
Purchasing Manager
City of Fairhope