

**ADDENDUM NO 02**  
CITY OF FAIRHOPE

**RFQ No. 002-16 Emergency Repairs to Library due to Lightning 07-15-15**

THE DOCUMENTS FOR THIS RFQ SHALL BE AMENDED, REVISED AND CHANGED IN THE FOLLOWING PARTICULARS:

**PARTS NEEDED FOR VAV BOXES AS OF 10-9-15, BEFORE DIAGNOSTICS REPORT**

1. 1-01 Discharge Air Temp Sensor Trane 4190-1111
2. 1-04 Zone Sensor Trane 4190-1090
3. 1-06 Heating Element Tutco DBL 20713-7.0-3P
4. 1-08 Heating Element Tutco DBL 20713-7.0-3P
5. 1-09 Heating Element Tutco DBL 20713-7.0-3P
6. 3-03 Heating Element Tutco DBL 20713-7.0-3P
7. 3-01 Zone Sensor Trane 4190-1090
8. 3-04 Discharge Air Temp Sensor Trane 4190-1111
9. 5-02 Discharge Air Temp Sensor Trane 4190-1111
- 10.5-03 Discharge Air Temp Sensor Trane 4190-1111
- 11.5-05 Discharge Air Temp Sensor Trane 4190-1111
12. 5-07 Discharge Air Temp Sensor Trane 4190-1111
- 13.5-08 Discharge Air Temp SensorTrane 4190-1111
- 14.6-01 Discharge Air Temp SensorTrane 4190-1111
- 15.6-03 Discharge Air Temp Sensor Trane 4190-1111
16. 6-04 Discharge Air Temp Sensor Trane 4190-1111
- 17.6-06 Discharge Air Temp Sensor Trane 4190-1111
- 18.6-08 Zone Sensor Trane 4190-1090
- 19.6-10 Discharge Air Temp Sensor Trane 4190-1111
20. Chiller Yard Outdoor Air Temp Sensor Trane 4190-1101

Bidders are to sign and include signed **Addendum No. 2** with submitted RFQ documents.

Acknowledged: Company \_\_\_\_\_

By \_\_\_\_\_

Daniel P. Ames  
Purchasing Manager  
City of Fairhope  
Posted: 10/09/15