

ADDENDUM NO 02
CITY OF FAIRHOPE
To
BID NO. 008-11
LIFT STATION
ODOR CONTROL CHEMICALS
FOR THE SEWER DEPARTMENT

The bid documents for this Bid shall be amended, revised and changed in the following particulars:
Answers from Sewer Department

CHANGE:

Remove existing page VII-3.
Insert page VII-3rev1 (attached below).

Remove existing page VII-2.
Insert page VII-2rev1 (attached below).

QUESTIONS FROM POTENTIAL BIDDERS:

1. Is calculated flow correct for Grand Hotel?

Answer: See attached new page VII-3rev1. with correct data.

2. Is an Alabama Contractor's License required to bid?

Answer: No. The Alabama Licensing Board for General Contractor's representative, Andrew Earl, confirmed this 01-28-11.

Bidders are to sign and include signed Addendum No.1 with submitted bid documents.

Acknowledged:

Company

By

Daniel P. Ames
Purchasing Manager
City of Fairhope
Posted : 01-28-2011

5.0 SPECIFICATIONS

5.0.1 Technical Specifications

Minimum Feed Sites	Flow Rate in Gallons per 30 days
Twin Beech #1 & #2 PS	6,666,000
Carya Point PS	882,000
Woodlands PS	6,540,000
Quail Creek PS #1	3,270,000
East of the Sun PS	4,389,000
White Grove PS	1,440,000
Thompson Hall PS	4,740,000
Grand Hotel PS	6,237,000
Baldwin 1 PS	672,000

- 5.0.1.1 All components of the system shall be compatible with chemicals such as salts and the conditions to which they are subjected to during the normal operation of the system. Compounds with which the materials must be compatible include, but are not limited to:

Hydrogen Sulfide
Biologically Reduced Sulfur Compounds

- 5.0.1.2 All components of the odor control program shall be provided by a single Contractor who shall be solely responsible for the program.
- 5.0.1.3 All supplied chemicals shall not create a matting effect in the lift stations.

5.0.2 Service Specifications

- 5.0.2.1 Contractor will service all locations on a bi-monthly, or as needed, basis, a minimum of twenty-four(24) site services per year.
- 5.0.2.2 The Contractor shall have the ability to analyze the system for proper odor control through a variety of physical and engineering controls employed during bi-monthly inspections, or more frequently, as needed. During each bi-monthly inspection, or as needed, the Contractor will test levels at all applicable locations.
- 5.0.2.3 The Contractor shall establish control points, and conduct physical testing, including atmospheric and wet chemical testing of the control points for odorous compounds.

- 3.0.2 The Contractor shall provide, with the bid submittal, a list of 5 wastewater facilities currently serviced by the Contractor for the control of hydrogen sulfide and other odor causing components associated with municipal wastewater systems. The list shall include correct names, phone numbers, and length of service.
- 3.0.4 The Contractor shall maintain regular production facilities at their place of business. These facilities shall be open for inspection by a representative of the Owner at any time during the duration of this contract.
- 3.0.5 Documentation of these requirements will be required prior to final award of a contract.

4.0 REPRESENTATIVE QUALIFICATIONS

- 4.0.1 The Contractor will designate a primary representative and technical support staff and will provide telephone, voicemail and email contact information for each.
- 4.0.2 Each of these contacts must be a certified wastewater technician, and have a minimum of ten years field experience in wastewater treatment. The Contractor will provide documentation of this certification and experience.
- 4.0.3 The contractor's primary representative will reside near enough to Fairhope, Alabama to respond on-site within two hours notification. The technical support staff is exempt from these requirements.
- 4.0.4 Documentation of these requirements will be required prior to final award of a contract.
- 4.05 Subcontractors, superintendents, foremen, and workers employed by the CONTRACTOR shall be competent and reliable. All workers must have sufficient skill and experience to properly perform the work assigned them. All workers engaged on special work or skilled work, in any trade, shall have had sufficient experience and ability in such work to perform it properly and satisfactorily and operate the equipment involved, and shall make due and proper effort to execute the work in the manner prescribed in Specifications and Contract. The OWNER may demand the dismissal of any persons employed by the CONTRACTOR in, about, or upon the Work who misconducts himself or is incompetent or negligent in the due and proper performance of his duty, or who neglects or refuses to comply with the directions given, and such person shall not again be employed hereon without the written consent of the OWNER. Should the CONTRACTOR continue to employ or re-employ any such person, the OWNER may withhold all monies, which are or may become due, or he may suspend the Work until the CONTRACTOR complies with such order.

VII-2 rev1

END OF ADDENDUM NO. 2