

ADDENDUM NO 01

CITY OF FAIRHOPE

To

Bid No. 032-10 WEATHERED STEEL POLES

For

Fairhope Electric Department

The bid documents for this Bid shall be amended, revised and changed in the following particulars:

CLARIFICATION:

Dimensions and moments listed in the bid are intended to be a representative of the type and size of poles being sought. Poles with engineered dimensions and moments that meet current NESC code requirements are acceptable.

Other groundline protection methods are acceptable. Painted applications, such as corrocote, as acceptable, as long as they are applied to a distance of 10% of the length of the pole plus 2 feet from the butt and have a minimum thickness of 16 mils.

Responders are to sign and include signed Addendum No.1 with submitted quotation documents.

Acknowledged:

_____ Company

_____ By

Daniel P. Ames
Purchasing Manager
City of Fairhope

Posted: 09-02-2010